

Les Chères, October 23<sup>rd</sup>, 2023

**Subject : Interpak junction box and BD4 Copak terminals**


**To whom it may concern**

**We hereby confirm the following :**

**It is acceptable to use an Interpak junction box to connect four 4x6mm<sup>2</sup> or 4x10mm<sup>2</sup> network cables, provided its installation on site is possible.**

**As manufacturer of the junction box, we confirm the possibility to install 4 BD4 Copak terminals with 4 inputs to connect 4 cables. However, it is the installer's responsibility to check whether the connection of all wires to the terminals is possible, given the limited space available inside the box.**

**Yours faithfully,**



**Thomas LANGLE**  
**Marketing Manager**